

R 286 F212-218


BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$29.00

TYPE BUILDINGS R-288 FH96-TRUSS

PERMIT NO. G-7729	LOCATION 6001 - Power Inn Road A-4 (51)
DATE Jul-30-70	PURPOSE Const. wood working building
ZONE M-2-S	OWNER Nikkel Moulding Co. same
	ARCH'T G. Porter
	CONTR Florin Enterprises, Inc. 6435 Florin-Perkin

VAL. \$4,700.	STORIES	ROOMS	APTS.	SIZE 2,400-sq. ft.
---------------	---------	-------	-------	-----------------------

INSP.	DATE	BLDG. TYPE V-no-hr. Spr.	OCCUPANCY GROUP E-3	PHONE (O) (C) 383-2505
-------	------	--------------------------	---------------------	---------------------------

FORM	2-31-70	Vault		
JOIST				
FRAME				
SHEET ROCK				
FINAL	9-21-70			

Ent

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
8.13.70	St. Hall - Improper Bracing
	SF 8.25.70 Court
8.28.70	PT Corrections mt. made Court
9.21.70	OK Truss details submitted - Court
	<p>COMPLETE AND OK</p> <p style="text-align: right;">INSPECTOR</p>