

*B116 7380-385*

W 5' of **BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD** \$73.00

the N.  $\frac{1}{2}$  of Lot 7 & 8 **TYPE BUILDINGS**  
 Allen & Leitch

PERMIT NO. <b>E-3243</b>	LOCATION <b>3250 - W Street</b>	<b>A-1</b>
DATE <b>Feb. 14-63</b>	PURPOSE <b>Const. new triplex</b>	
ZONE <b>R-4</b>	OWNER <b>Scribner Gregory Bldrs. 4550-24th St</b>	
	ARCH'T	
	CONT'R <b>Owner</b>	<b>Same</b>
		<b>GL 6-7355</b>

VAL. <b>\$22,000.</b>	STORIES <b>2</b>	ROOMS <b>21</b>	APTS. <b>3</b>	SIZE <b>1,300 sq. ft.</b>
-----------------------	---------------------	--------------------	-------------------	------------------------------

INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP
FORM	<i>5-20-63</i>	<i>Alley</i>	
JOIST			
FRAME	<i>7-9-63</i>	<i>Const</i>	
SHEET ROCK	<i>7-8-63</i>	<i>Hammay</i>	
FINAL	<i>10-21-63</i>	<i>R. C. Co.</i>	<i>Ent Com.</i>

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
5-15-63	Pt No plans. Muddalls not laid out. No address sign <span style="float: right;">Fuller</span>
5-17-63	Pt Footing not deep enough No muddalls <span style="float: right;">Court</span>
5-29-63	OK slab <span style="float: right;">Fuller</span>
7-9-63	OK roof nail <span style="float: right;">Court over</span>
8-5-63	Pt Muddalls to low on stairway
	<div style="display: flex; justify-content: space-between;"> <span>COMPLETE AND OK</span> <span>INSPECTOR</span> </div>