

R235 F247-249

| BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD | | | | | \$52.00 |
|--|----------|--|---------|-----------------|----------------|
| N. 56.91 ft. of Lot 59 Edward Coyle Tract | | | | | TYPE BUILDINGS |
| PERMIT NO. | | | | | |
| F-9911 | LOCATION | 4631 - 24th Street | | | A-3 (35.01) |
| DATE | PURPOSE | Const. radiator repair shop. | | | |
| 3/27/68 | OWNER | Gene Higgins same | | | |
| ZONE | ARCHT | Leo McGlad 2011 Arden Way | | | |
| M-1 | CONTR | Porter & Porter Const. 3732 Marshall A-2 | | | |
| VAL. \$14,600. | STORIES | ROOMS | APTS. | CARM. | SIZE |
| | | | | | 1482 sq. ft. |
| INSP. | DATE | BLDG. TYPE | V No Hr | OCCUPANCY GROUP | PHONE (O) (C) |
| | | | | F-2 | 944-3001 |
| FORM | 4-17-68 | Karpov 5-2-68 OK slab Callaway | | | |
| JOIST | | | | | |
| FRAME | 5-16-68 | Karpov | | | |
| SHEET ROCK | 5-20-68 | Callaway | | | |
| FINAL | 6-17-68 | [Signature] | | | |

| DATE | SPECIAL CONDITIONS OF WORK — REMARKS |
|---------|--|
| 4-23-68 | BB called - nothing <i>Count</i> |
| 4-23-68 | OK P BB <i>Larsen</i> |
| 4-24-68 | OK B BB <i>Larsen</i> |
| 4-25-68 | OK base & top BB <i>Larsen</i> |
| 5-7-68 | P.T. Roof nail L Block for shear transfer. Nail all edges. Put down paper barrier between plywood on office deck & base |
| 5-9-68 | OK Roof nail - <i>Larsen</i> |
| 5-15-68 | P.T. <i>Optima</i> - nailing for deck. <i>Triangles</i> <i>not corrected</i> <i>Larsen</i> |
| 12-68 | P.T. <i>large</i> packing. Fill holes in R.C. <i>Larsen</i> |
| | |
| | COMPLETE AND OK INSPECTOR |

