

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. <i>A-1728</i>	LOCATION <i>2932 - 35th Street</i>			
DATE <i>6/7/34</i>	PURPOSE <i>To hang - new PHONES Etc.</i>			
ZONE <i>Gen. Com</i>	OWNER <i>High Altitude Building Co</i>			
	ARCH'T <i>Golden West Heating Co</i>			
VAL. <i>185⁰⁰</i>	CONT'R <i>Golden West Heating Co</i>			
	STORIES	ROOMS	APTS.	SIZE

Light Shafts	Elevator Shafts
Vent Shafts	Boiler Rooms
Owner's Inspector	Sprinkler System
Lath	Gas Vents
Fire Escapes	Chimneys
Stand Pipes	Skylights

DATE	CONDITION OF WORK-REMARKS
6/7/34	<p>Instructed Home Electricians to hang 10 ft above sidewalk and 2 1/2" from frame Face of Comb. Dr. Wall. Owners representative agreed to install 2 x 4 brace at end of frame fire wall & brace same for wind pressure.</p>
	<p>O.K. A.W. Campbell</p>
	<p>_____</p>
6/7/34	<p>COMPLETE AND O.K. <i>A.W. Campbell</i> INSPECTOR</p>