

R 89-7638

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD \$6.00

TYPE BUILDINGS

PERMIT NO. D-9660	LOCATION 2200 - 60th Street	A-1		
DATE Sep 26-61	PURPOSE Replace fire damaged carport			
ZONE	OWNER Mrs. Clark D. Ryder	2800-Regina Way		
	ARCH'T	IV 3-2352		
	CONT'R	John C. Tull 2990 - Anderson Way		
VAL. \$1,000.00	STORIES	ROOMS	APTS.	SIZE 768 sq. ft.
INSP.	DATE	INSPECTOR		
FORM				
JOIST				
FRAME				
LATH				
FINAL	8-30-61	J. Habratis		

DATE	SPECIAL CONDITIONS OF WORK—REMARKS
10-17-61	Pl. Trial. Improp. removal. No blocking over bearing & center of 2x8 c. post. Removal shut socket without inspection given
1-31-62	Corrections still not made at this date. And notice Ribs
2-1-62	Notice sent. At
2-9-62	Call contractor. Have him put in center blocking through ceiling Ribs
COMPLETE AND OK	INSPECTOR