

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. 8224	LOCATION 3421 J. St
DATE June 30 1931	PURPOSE Remove old "Kellastone" Garage & 1/2 Store Ext. of DWG.
ZONE Multiple Family	OWNER ROSE BORIES San Francisco, Calif
	ARCH'T
	CONT-R P. W. DANIELS 1572 - 53rd St.

VAL. 440⁰⁰	STORIES 2	ROOMS	APTS. 4	SIZE
---------------------------------	---------------------	-------	-------------------	------

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE	CONDITION OF WORK-REMARKS
7/1/31	<p>Made Partial Strip of D.W.C. Old Kellstone Stucco Plaster over wood lath to be removed. 2-Ply Old Paper applied. Tutted with 12-gauge galv. Brackets wire and Cement Plastered with 2 coats. Smooth Plaster to be applied as per D.M. Code. Here to be noted with 12-gauge wire. Strong wood lath</p>
7/29/31	<p>3rd / 14 SP. EXT LATH IN PLACE ^{Very good job OK} Alfred Campbell</p>

COMPLETE
AND O.K.

INSPECTOR