

R310 F 50-576

## BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$170.50

TYPE BUILDINGS REO R383F397-403  
(Copy of Original)

|                      |   |                          |                               |                       |
|----------------------|---|--------------------------|-------------------------------|-----------------------|
| PERMIT NO.<br>H-3200 | LOCATION<br>906 - 2nd Street                      | A2 (7)                   |                               |                       |
| DATE<br>Sept. 14-71  | PURPOSE<br>Make structural repairs & int. alt. to |                          |                               |                       |
| ZONE<br>M-1          | OWNER<br>Robert C. Cook /office bldg. & inst.     |                          |                               |                       |
|                      | ARCH'T<br>W. J. Alexander                         | Sacto./covered walkway   |                               |                       |
|                      | CONT'R<br>Owner                                   | Same 444 8200            |                               |                       |
| VAL. \$60,000.       | STORIES<br>2                                      | ROOMS                    | APTS.                         | SIZE<br>5,715 sq. ft. |
| INSP.                | DATE  | BLDG. TYPE<br>III - 1 Hr | OCCUPANCY GROUP<br>F-2<br>B-3 | PHONE (O) (C)         |
| FORM                 | 12-17-71  | OK 8' 73.73 Laven        |                               |                       |
| JOIST                |   |                          |                               |                       |
| FRAME                |   | Disturbed letter sent    |                               |                       |
| SHEET ROCK           | 4-25-73 Callie                                    | 1-25-74 Callaway         |                               |                       |
| FINAL                | 4-12-74   | McCalloway               |                               |                       |

| DATE     | SPECIAL CONDITIONS OF WORK — REMARKS                          |
|----------|---|
| 11-5-71  | Steel - not ready <i>Lower</i>                                |
| 12-7-71  | Steel for full wall <i>Lower</i>                              |
| 12-23-71 | OK ground - full walls <i>Lower</i>                           |
| 1-5-72   | OK ground for full wall <i>Lower</i>                          |
| 2-9-72   | OK slab - OK 4.5.3 for ground, OK roof<br>Boards <i>Spine</i> |
| 3-20-72  | 2nd floor - glass joint <i>Spine</i>                          |
| 3-22-72  | OK frame transferred only <i>Ground</i>                       |
| 3-29-72  | OK steel & frame <i>Spine</i>                                 |
| 4-14-72  | OK slabs <i>Spine</i>   |
| 4-28-72  | OK 1st & 2nd vertical channels <i>Spine</i>                   |
| 4-28-72  | Temporary certificate of occupancy issued <i>Spine</i>        |
| 5-1-72   | OK temporary final - issued only <i>Spine</i>                 |
| 2-6-73   | COMPLETE 30 days<br>AND OK <i>Callahan</i><br>INSPECTOR       |

## BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$170.00

## TYPE BUILDINGS

|                |   |                        |                            |               |
|----------------|---|------------------------|----------------------------|---------------|
| PERMIT NO.     |   |                        |                            |               |
| H-3200         | LOCATION 906 - 2nd Street A2 (7)                          |                        |                            |               |
| DATE           | PURPOSE Make structural repairs & int. alt. to off. bldg. |                        |                            |               |
| 9-14-71        | OWNER Robert C. Cook / cover walkway                      |                        |                            |               |
| ZONE           | ARCH'T W. J. Alexander Sacto.                             |                        |                            |               |
| M-1            | CONT'R Owner Same 444-8200                                |                        |                            |               |
| VAL. \$60,000. | STORIES   | ROOMS                  | APTS.                      | SIZE          |
|                | 2   |                        |                            | 5,715 sq. ft. |
| INSP.          | DATE  | BLDG. TYPE III - 1 Hr. | OCCUPANCY GROUP B-2<br>B-3 | PHONE (O) (C) |
| FORM           |   |                        |                            |               |
| JOIST          |   |                        |                            |               |
| FRAME          |   |                        |                            |               |
| SHEET          |   |                        |                            |               |
| ROCK           |   |                        |                            |               |
| FINAL          |   |                        |                            |               |

| DATE    | SPECIAL CONDITIONS OF WORK — REMARKS  |
|---------|---|
| 3-8-73  | They are still working S.F. Under<br>April 9 1973 Calloway  |
| 1-15-74 | Pt. panic hardware required on exits<br>doors - not. acc. load 100 lbs. required Calloway             |
| 1-25-74 | P.I. Find - occupied without final insp. Calloway   |
| 2/28/74 | Received letter S.F. to 3/11/74 cl. the Calloway  |
| 3-12-74 | S.F. has panic hardware panic hardware<br>in office S.F. to 4-12-74 cl. the Calloway                  |
| 3-23-74 | S.F. 4-12-74 they are working Calloway  |
|         |   |
|         | <p data-bbox="305 798 435 850">COMPLETE<br/>AND OK</p> <p data-bbox="1159 826 1289 850">INSPECTOR</p> |