

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. B-10438	LOCATION 279 - 325 - 29th Street
DATE 6/9/42	PURPOSE Repairs to dwg. surface concrete
ZONE	OWNER W. A. Travis
	ARCH'T.
	CONT'R. Owner

VAL. 3500⁰⁰	STORIES	ROOMS	APTS.	SIZE
LIGHT SHAFTS		ELEVATOR SHAFTS		
VENT SHAFTS		BOILER ROOMS		
OWNER'S INSPECTOR		SPRINKLER SYSTEM		
LATH		GAS VENTS		
FIRE ESCAPES		CHIMNEYS		
STAND PIPES		SKYLIGHTS		

DATE	CONDITION OF WORK--REMARKS
6/18/42	<p>3rd / 4th FLOOR EXT LATH FOR RE-STUCCO PLASTERING exterior of Dwlg after corner removed Old "Hoffite" Plaster applied to wood lath. Lather covered lath with 15 lb felt paper and 18 gauge gal wire mesh nailed 16" on centers horizontally and 6" vertically to studs. ready for Cement Stucco Plaster.</p> <p style="text-align: right;">O.K. A.W. Campbell</p>
	<p>COMPLETE AND O. K.</p> <p style="text-align: right;">INSPECTOR</p>