

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. <i>B-25977</i> DATE <i>7-29-49</i> ZONE	LOCATION <i>4200- N street</i> PURPOSE <i>Erect bldg. for offices</i> OWNER <i>Robt. Neumann</i> ARCH'T. CONT'R. <i>Frank Maloney</i>
--	---

VAL. # <i>14000</i>	STORIES	ROOMS	APTS.	SIZE
---------------------	---------	-------	-------	------

LIGHT SHAFTS		ELEVATOR SHAFTS	
VENT SHAFTS		BOILER ROOMS	
OWNER'S INSPECTOR		SPRINKLER SYSTEM	
LATH		GAS VENTS	
FIRE ESCAPES		CHIMNEYS	
STAND PIPES		SKYLIGHTS	

DATE

CONDITION OF WORK-REMARKS

8/5/49

Ferm Insp. *J. E. Jones*

9/8/49

Frame " (3 of kick blocks not installed and 1/2 of those installed are incorrect) *P. E. Richards*

COMPLETE AND O. K.

INSPECTOR