

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0013409

Insp Area: 1

Site Address: 2208 24TH ST SAC

Parcel No: 010-0165-011

Sub-Type: RES

Housing (Y/N): N

CONTRACTOR

KLM ROOFING
2471 EL PAVO WY
RANCHO CORDOVA, CA 95670

OWNER

OLIVEIRA MARY T
LIVE OAK CA
95953

ARCHITECT

Nature of Work: REROOF, INSTALL 20SQ OF 25YR LAM DIM COMP

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C-39 License Number 644890 Date 11-8-00 Contractor Signature Ken Matson

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

____ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

____ I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 11-8-00 Applicant/Agent Signature Ken Matson

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued

____ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier _____ Policy Number _____ Exp Date _____

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 11-8-00 Applicant Signature Ken Matson

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

IR- 2208 24th STREET

TO SACRAMENTO CITY BUILDING DEPARTMENT

KLM ROOFING IS WITHDRAWING FROM
IT'S PERMIT # 0013409 FOR JOB AT
LOCATION 2208 - 24th STREET. DUE TO
THE OWNER'S LACK OF CO-OPERATION IN
CLEARING UP CORRECTION NOTICE. THERE
WERE ARTICLES HE NEED TO TAKE CARE OF
BEFORE WE COULD CONTINUE. AND TIM HASSON
HAS NOT TAKEN CARE REMOVAL OF CHIMNEY
OR INSTALLATION OF PIPES THUR THE ROOF.
ALL OTHERS WERE FIXED AS REQUESTED.

KLM ROOFING
LIC # 644890

Ken Matson

PERMIT NO.

0013409

CITY OF SACRAMENTO
1231 I ST. ROOM 200
BUILDING INSPECTIONS DIVISION

AREA NO.

1

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-5191 FOR REINSPECTION OF WORK.

JOB LOCATION 2208 24TH ST.

INSPECTION REQUESTED IN-Progress

THE UNDERSIGNED BUILDING PLUMBING MECHANICAL ELECTRICAL
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE
FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

1. 4" soil stack has Improper Flashing (6") - 4" BASE
Flashing - 4" CODE CAP REQUIRED - ALSO: EXTEND ~~Flashing~~
THEORY BASE FLASHING - Counterflash - METAL cone soil skirt
or rubber collar
2. 1/2" soil stack NEEDS BASE FLASHING
3. Ridgeglass HAS N-19 OR N-17(S) - NEEDS COIL NAILS
OR ROOFING NAILS - 1/2" OR 3/4" - Re-nail
4. Step-Flash FIREPLACES
5. Drip edge IS NEEDED ON Porch overhang

INSPECTOR

Stephen Edwards

DATE

4/23/01

BUILDING INSPECTIONS 264-5716

INSPECTOR'S COPY